

CROSS SECTION OF TANK SHELL


SCALE 1:25

RETAINING WALL REINFORCEMENT

SCALE 1:25

SUMP REINFORCEMENT


SCALE 1:25



SECTION OF ELECTRICAL DUCT

SCALE 1:25

POS. # NO. mm	LENGTH M.	NULL	LENGTH PER POSITION M.				
			Ø 10	Ø 14	Ø 16	Ø 25	
BROUGHT FORWARD							
1 16	2.40	1500					
2 16	1.40	1125			3600		
3 25	84.00	10			1575		
4 16	78.00	12			840		
5 14	70.25	3			936		
6 14	83.10	3			210.75		
7 16	75.21	4			249.3		
8 16	81.77	4			300.84		
9 16	3.50	1760			327.08		
10 16	4.50	1760			6160		
11 14	-	-			7920		
12 10	0.50	1104	552		13596		
13 16	4.00	96			394		
14 16	2.00	44			88		
15 16	5.00	44			220		
16 14	1.30	120			156		
17 14	1.00	120			120		
18 14	1.15	240			276		
19 10	-	-	432				
CARRIED FORWARD							
TOTAL LENGTH M.	984	14608.0521510.92	840				
UNIT WEIGHT kg/m	0.617	1.208	3.853				
TOTAL WEIGHT kg	607.13	17846.523944.23	3236.52				
GRAND TOTAL - KGS.			55434 - Kg				

Drawing Title: HEAVY FUEL OIL STORAGE TANK REINFORCEMENT DETAILS										Customer: PAYVAND_E_GOLESTAN									
General Arrangement Drawing																			
 IRAN INDUSTRIAL DESIGN CO.				—		Date		Signature		Rev.		Description		By		Date			
				Designed		M/W/1		ARZAMAN		0		—				A.A.		8/9/2	
				Drawn		M/W/2		ROSHDI											
				Checked				ARZAMAN											
				Approved				ROSHDI											
Project No.:				353		Scale :		Drawing No.:		1.353.ST.14.5.05.00		0		Rev.					